

VILLAGE OF BATH

INDUSTRIAL USER PERMIT

In accordance with the Village of Bath Sewer Use Law,

Permittee:

Steuben County - Leachate Treatment Facility
3 East Pulteney Square
Bath, New York 14810

is hereby authorized to discharge industrial wastewater from the above identified facility and through the outfall identified herein into the Village of Bath sewer system in accordance with the conditions set forth in this permit. Compliance with this permit does not relieve the Steuben County Leachate Treatment Facility of its obligation to comply with any or all applicable pretreatment regulations, standards or requirements under local, State, and Federal laws, including any such regulations, standards, requirement, or laws that may become effective during the term of this permit.

Noncompliance with any term or condition of this permit shall constitute a violation of the Village of Bath Sewer Use Law.

This permit shall become effective on June 15, 2012, and shall expire at midnight on June 15, 2013.

By

Harold J. Rodbourn, Chairman
Municipal Utility Commission

Permit No. 402
Issued this 15th day of June, 2012



PART I EFFLUENT LIMITATIONS

- A. During the period of June 15, 2012 through June 15, 2013, the Steuben County Leachate Treatment Facility is authorized to discharge treated wastewater to the Village of Bath sewer system from the outfall listed below.

Description of outfall:

Outfall	Description
001	Discharge of 108,000 GPD max. of treated leachate from the Effluent Equalization Tank

- B. During the period of June 15, 2012, through June 15, 2013, the discharge from Outfall 001 shall not exceed the following effluent limitations. Effluent from this outfall consists of treated wastewater.

Effluent Limits - Outfall 001

<u>Parameter</u>	<u>Daily Maximum</u>
Flow	108,000 gpd
Flow (annual avg.)	88,000 gpd
pH	6.0 to 9.0 SU
BOD	300 mg/l
TSS	300 mg/l
NH3	50 mg/l
Oil & Grease	100 mg/l
Phenol	Monitor mg/l
Cyanide	Monitor mg/l
Arsenic	Monitor mg/l
Copper	Monitor mg/l
Cadmium	Monitor mg/l
Chromium	Monitor mg/l
Nickel	Monitor mg/l
Lead	Monitor mg/l
Molybdenum	Monitor mg/l
Mercury	Monitor mg/l
Selenium	Monitor mg/l
Zinc	Monitor mg/l
Volatiles	Monitor mg/l
(Method 8240)	
Semi-volatiles	Monitor mg/l
(Method 8270)	
Pesticides	Monitor mg/l
(Method 8080)	

